



City of Elko
1751 College Avenue
Elko, NV 89801
Ph. 775-777-7110

**ELKO MOUNTAIN BOOSTER STATION & WATERLINE PROJECT -
ARPA**

ADDENDUM NUMBER ONE

February 28, 2024

Please confirm receipt of ADDENDUM NUMBER ONE AND FAX BACK TO (775) 777-7129 or email to cityclerk@elkocitynv.gov.

SIGNATURE

COMPANY NAME

DATE

Elko City Clerk Kelly
Wooldridge

***** PLEASE NOTE RECEIPT OF ADDENDUM NUMBER ONE ON APPLICABLE
LINE ON SUBMITTED BID PROPOSAL**



February 26, 2024

City of Elko
Utilities Department
1751 College Avenue
Elko, NV 89801

Re: ARPA – Elko Mountain – Booster Pump Station & Water Line Project

All Language listed in Addendum No. 1, shall supersede all language found in the provided project Plans & Specifications.

Questions Submitted

1. What are the site conditions? Elevation & ambient temperature design are what I need.
✚ – 5400ft at 90 degrees F
2. What size/runtime fuel tank will be required? Keep in mind you need to stay under 660 gallons for indoor tanks.
✚ – 24-hour runtime, approximately 545 gallons based on quote from Empire CAT
3. Will a remote fuel-fill station be required?
✚ Yes, contractor to ensure a fully operational system
4. What is the size of the generator room?
✚ Generator room is 8'-8" x 17'-4", see plan sheet D2.2 for layout.
5. What level of sound attenuation does the exhaust silencer need to have?
✚ Minimum of 25 dBA reduction
6. Will the ATS be indoors or outdoors?
✚ Outdoors
7. Are there any specifics on the ATS that we need to quote?
✚ High level requirements, consider the following: 480/277V, 60Hz, 3-phase, 4-wire, open transition, 4-pole (switched neutral), NEMA 3R enclosure. (See sheet E0.3 for Online Diagram)
8. Has the pump skid system already been purchased? If not will an alternate manufacturer such as Tigerflow Systems of Dallas, Texas be considered.
✚ The following will be required, within the next 30 days to be considered as an alternative.
 - A. The system will have to be approved by NDEP
 - B. The system will have to be NSF 61 compliant and certified with proof of certification
9. What is the path for Tigerflow to obtain pre approval before the bid date?
✚ See answer above

10. Is “Buy American” or any similar Federal Acquisition Requirements part of this project?
✚ No, see contract documents for specifics.

11. Please see attached Stamped Electrical Plans

END OF Section
