



City of Elko Clerk's Department
1751 College Avenue
Elko, NV 89801
(775) 777-7126
FAX (775) 777-7129

ADDENDUM NUMBER TWO

EXIT 298 SEWER – PHASE 2

Please confirm receipt of ADDENDUM NUMBER TWO AND FAX BACK TO (775) 777-7129 or email to cityclerk@elkocitynv.gov.

RECEIVED:

SIGNATURE

COMPANY NAME

Dated this ____ day of June, 2022.

Elko City Clerk

Kelly Wooldridge

***** PLEASE NOTE RECEIPT OF ADDENDUM NUMBER TWO ON
APPLICABLE LINE ON SUBMITTED BID PROPOSAL *****



**CITY OF ELKO
ENGINEERING DEPARTMENT
1755 COLLEGE AVENUE
ELKO, NEVADA 89801
(775)777-7210
(775)777-7219 FAX**

ADDENDUM #2
EXIT 298 SEWER – PHASE 2

PWP# EL-2022-365

JUNE 22, 2022

This addendum addresses additions, changes, and clarifications to the Contract Documents and Contract Drawings for the City of Elko, Exit 298 Sewer Phase 2 project.

CHANGES:

1. Welded C900 PVC pipe may be used as the carrier pipe inside the steel bore casings. The rough interior edges of the welds would be required to be smoothed per the manufacturer's recommended methods. This is offered as an option to the cement lined ductile iron pipe as noted in Detail A, on Sheet 10.
2. A revised set of drawings is attached hereto. Minor changes have been made to reflect items in Addendums #1 and #2.

CLARIFICATIONS:

1. The City of Elko has obtained the County permit to work along Shooting Range Road. The Contractor will not be required any additional County permits. Contractor is required to follow Elko County Code 8-1-13 when working within County rights-of-way.
2. At a minimum, one public travel lane must be maintained along Shooting Range Rd. at all times.
3. A question was raised regarding removal and replacement of fencing along the NDOT right-of-way. I asked Rhonda Morfin at our local District 3 office about this. Her response was "All fencing will be maintained with no breaks to ensure no livestock will reach I80." After further discussion and a request for clarification, I have been unable to get any more clarification. If additional information becomes available, it will be shared.

Thank you for your interest in bidding this project.

Page 2 of 2

Sincerely,

Bob Thibault

Bob Thibault, P.E., P.L.S.
City of Elko
Civil Engineer