

Village of Hinsdale
19 E. Chicago Avenue
Hinsdale, IL 60521-3489
(630)789-7000

Village Website: www.villageofhinsdale.org

PUBLIC SERVICES UTILITY PERMIT APPLICATION

Date of Application: 05/22/20 Permit No: ComEd0033 Permit Expiration Date: 11/2020

Utility Company Information:

Company Name: ComEd
Address: 1910 S Briggs Street
City, State, Zip: Joliet, IL 60433
Contact Person: Kurt Armstrong
Phone Number: 815 724-5184
Email Address: kurt.armstrong@comed.com
Cell Number: 815 546-4119
Project/Work Order Number: 16508148

Contractor Information:

Company Name: _____
Address: _____
City, State, Zip: _____
Contact Person: _____
Phone Number: _____
Email Address: _____
Cell Number: _____

PROJECT LOCATION: 8th Street west of Vine Street

Description of work covered under this permit: Modifications to an existing pole and trimming (3) adjacent trees which have grown into the wires.

Start Date: to be determined in 2020

Completion Date: 2021

Site Plan/Details/Specifications (3 sets) included with application?

☒ YES ☐ NO

Certificate of Insurance included with application?

☐ YES ☒ NO

Type of Utility:

☒ ComEd

☐ Nicor

☐ Comcast

☐ Water

☐ Sewer

☐ Communications:

☐ Fiber Optic

☐ Wireless

☐ Other:

Applicant Information:

Kurt Armstrong

Print Name: same as above

Phone Number: _____

Company: _____

Email Address: _____

Signature: _____

Date: _____

ALL CONSTRUCTION SHALL BE DONE IN ACCORDANCE WITH THE LATEST EDITION IN EFFECT ON THE DATE OF PERMIT APPLICATION OF THE FOLLOWING: STANDARD SPECIFICATIONS FOR ROAD AND BRIDGE CONSTRUCTION & SUPPLEMENTAL SPECIFICATIONS AND RECURRING SPECIAL PROVISIONS BY THE ILLINOIS DEPARTMENT OF TRANSPORTATION, ILLINOIS MANUAL ON UNIFORM TRAFFIC CONTROL DEVICES FOR STREETS AND HIGHWAYS, STANDARD SPECIFICATIONS FOR WATER AND SEWER MAIN CONSTRUCTION IN ILLINOIS, AND THE VILLAGE OF HINSDALE SUBDIVISION ORDINANCE AND ENGINEERING STANDARDS.

Village Use Only

Permit Approved:

☒ YES

☐ NO

Conditions for Approval/Reasons for Denial:

All disturbed Areas to be restored within 14 Days.

Approved By: _____

A. Diaz

Date: _____

5/26/20



An Exelon Company

ComEd
Southern Regional Engineering Department
1910 S. Briggs Street
Joliet IL 60433

Page 1 of 4

PERMIT APPLICATION TO PERFORM WORK

| | | | |
|------------------------------------------------|----------------------|--------------------------|-----------------------|
| COUNTY: | <u>DuPage</u> | WORK TASK #: | <u>16508148</u> |
| CO RTE/STREET | <u>8th</u> | P L #: | <u>465123</u> |
| TOWNSHIP: | <u>Downers Grove</u> | TOWNSHIP CODE: | <u></u> |
| MUNICIPALITY: | <u>Hinsdale</u> | SECTION: | <u>12</u> |
| TO: <u>Village of Hinsdale</u> | | COMED ENGINEER | <u>Kurt Armstrong</u> |
| <u>Attn: Public Services & Engineering</u> | | PHONE #: | <u>815-724-5184</u> |
| <u>19 E. Chicago Ave</u> | | WORK TO BE STARTED: | <u>TBD 2020</u> |
| <u>Hinsdale, IL 60521</u> | | WORK TO BE COMPLETED BY: | <u>TBD 2021</u> |
| <u>630-789-7382</u> | | | |

APPLICATION IS HEREBY MADE BY COMED FOR PERMISSION TO PERFORM WORK AS SPECIFIED BELOW:

Reframing two existing poles. Directional boring under 8th Street to facilitate a cable replacement. See the attached sketches for details. Trim trees along 8th Street.

REASON FOR WORK:
2020 Summer Critical

DATE: _____
E-MAIL ADDRESS Kurt.Armstrong@ComEd.com

PERMIT GRANTED




























SIGNED: _____ DATE: _____

PERMIT NUMBER: _____

ComEd Number: 8160

SKETCH SYMBOLS

PG 2 OF 4

| | |
|-------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------|
|  | EXISTING POLE (HALF SHADED ● INDICATES IBT 1/2 OWNERSHIP) (◎ INDICATES CUSTOMER OWNED POLE) |
|  | PROPOSED POLE |
|  | EXISTING POLE TO BE REPLACED |
|  | EXISTING DOWN GUY AND ANCHOR |
|  | PROPOSED DOWN GUY AND ANCHOR |
|  | REMOVAL SYMBOL |
|  | EXISTING OVERHEAD PRIMARY CIRCUIT |
|  | PROPOSED OVERHEAD PRIMARY CIRCUIT |
|  | EXISTING POLE MOUNTED TRANSFORMER |
|  | PROPOSED POLE MOUNTED TRANSFORMER |
|  | POLE MOUNTED TRANSFORMER TO BE REPLACED |
|  | EXISTING CABLE TERMINAL POLE (DOWN FEED) |
|  | PROPOSED CABLE TERMINAL POLE (DOWN FEED) |
|  | EXISTING SERVICE DROP OR SECONDARY AERIAL CABLE |
|  | PROPOSED SERVICE DROP OR SECONDARY AERIAL CABLE |
|  | EXISTING OPEN WIRE SERVICE DROP OR SECONDARY |
|  | EXISTING UNDERGROUND PRIMARY CABLE |
|  | PROPOSED UNDERGROUND PRIMARY CABLE |
|  | EXISTING UNDERGROUND SECONDARY OR SERVICE CABLE |
|  | PROPOSED UNDERGROUND SECONDARY OR SERVICE CABLE |
|  | EXISTING PAD MOUNTED TRANSFORMER |
|  | PROPOSED PAD MOUNTED TRANSFORMER |
|  | PAD MOUNTED TRANSFORMER TO BE REPLACED |
|  | CABLE PROTECTION TUBES OR CONDUITS |
|  | SPLICE PIT |
|  | EXISTING METER ENCLOSURE |
|  | PROPOSED METER ENCLOSURE |

WO # 16508148

VILLAGE OF HINSDALE UTILITY WORK PERMIT SKETCH

PG 3 OF 4

OP MAP: W3607-2, 4KV & 12KV
 AREA MAP: 465-125
 COMED PROJECT MANAGER: MIKE KING @ 815 724-5715




© 2015 ComEd Company

| Permit Type | Project Name | Office | Designer | Location - Reason For Work | Work Order # |
|-----------------------|------------------|------------|----------------|-----------------------------------------|-----------------|
| VILLAGE | 0000274805 | JOLIET | KURT ARMSTRONG | 8TH AND VINE STREET | 16508148 |
| Permit Number | SR # | JWA # | Phone # | SC 2021 - 6P210401 - 4-12 CONV ON W3607 | Schedule Group |
| 8160 | 06013705 | N/A | 815 724-5184 | Town or Township | 611C, 611L, 61X |
| Joint Work Contact | SER/CWA # | Phone RO # | PI # | HINSDALE | Q5/Block |
| - | N/A | 6P210401 | 6P210401 | Completed By: | 465123 |
| Date Issued: 04-27-20 | Confingent WO #s | N/A | Verified By: | Date: | |

0.0 100.0 200.0 FT

Page 1 of 2

Date:



| | | | | | |
|-----------------------|-----------------|------------|----------------|-----------------------------------------|----------------|
| Permit Type | Project Name | Office | Designer | Location - Reason For Work | Work Order # |
| VILLAGE | 0000274805 | JOLIET | KURT ARMSTRONG | 8TH AND VINE STREET | 16508148 |
| Permit Number | SR # | JWA # | Phone # | | Schedule Group |
| 8160 | 09013705 | N/A | 815 724-5164 | SC 2021 - 6P210401 - 4-12 CONV ON W3607 | 6HC, 6HU, 6HX |
| Joint Work Contact | SER/CWA # | Phone RO # | PD # | Town or Township | OS/Block |
| | N/A | N/A | 6P210401 | HINSDALE | 485123 |
| Date Issued: 04-27-20 | Contingent WO # | | | Completed By: | Date: |
| | N/A | | | Verified By: | Date: |



NOTES

LABEL ALL FACILITIES PER SPEC C7493

TEMPORARILY REMOVE AND REPLACE ANY FENCING SECTIONS TO ALLOW FOR CONSTRUCTION

LOC 1 : POLE # 022 - REMOVE THE 3.1 TRANSFORMER AND ALL ASSOCIATED COMPONENTS. REFRAME THE POLE AS A TWO WAY DEAD END POLE

LOC 2 : POLE # 022 - REMOVE EVERYTHING FROM THE POLE EXCEPT THE STREET LIGHT WIRE ATTACHMENT. REFRAME THE POLE AS A SINGLE PHASE DOWNFEED POLE.

LOC 3 : POLYPIPE PIT REFERENCE

LOC 4 : POLYPIPE REFERENCE

LOC 5 : CABLE FROM LOC 2 TO LOC 6

LOC 6 : XFMR 3D6 - REPLACE THE EXISTING TRANSFORMER WITH NEW. IF IT IS DESIRED TO RAISE THE TRANSFORMER, REMOVE THE EXISTING TRANSFORMER PAD AND REPLACE IT WITH A NEW PAD. DISCONNECT THE EXISTING PRIMARY CABLE AND CUT OFF AT GRADE. CONNECT THE NEW PRIMARY CABLE. DISCONNECT / RECONNECT THE SECONDARY CABLING.

LOC 1 TO LOC 2 : REMOVE THE EXISTING PRIMARY AND NEUTRAL WIRES. REPLACE WITH NEW 1/0 ALA WIRE.

LOC 2 TO LOC 3 : DIRECTIONAL BORE A 4" POLYPIPE FROM THE DOWNFEED POLE TO THE EASEMENT SOUTH OF THE SIDEWALK. PULL IN THE NEW CABLE.

LOC 3 TO LOC 6 : DIRECTIONAL BORE IN A NEW #2 AL CABLE FROM THE BORE PIT TO XFMR 3D6. LENGTH IS APPROXIMATELY 265 FEET.

LOC 2 TO LOC 6 : ABANDON THE EXISTING PRIMARY CABLE

REF SAG TABLE 61D