



**Addendum No. 2 to ITB 2022-36
Panacea Evacuation Route Road Project
(Jer-Be-Lou Boulevard to US Highway 98)**

Issued December 12, 2022

SECTION 1.0 SCHEDULE OF EVENTS

Failure to comply with this or any other paragraph of this ITB shall be sufficient reason for rejection of the Bid.

All times listed in the Schedule of Events are Eastern Standard Time (EST).

<i>Event</i>	<i>Date/Time</i>
Bid Advertisement Date	November 17, 2022
Release of Invitation to Bid	November 17, 2022
Mandatory Pre-Bid Conference	November 29, 2022 @ 10:00 A.M.
Bid Questions Due from Prospective Bidder	December 6, 2022, by 5:00 P.M
Responses to bid questions due	December 13, 2022
BIDS DUE TO BOCC	December 19, 2022 @ 3:00 P.M.
Posting of Intended Award	December 22, 2022
Board Consideration of Intended Award	January 17, 2023
Posting of Notice of Award	January 18, 2023

This addendum is being posted to provide responses to the questions that were received.

**ITB 2022-36 PANACEA EVACUATION ROUTE ROAD PROJECT
(JER-BE-LOU BOULEVARD TO US HIGHWAY 98)
ADDENDUM NO.2**

**Questions due December 6th and responses to proposal questions due on or before
December 13th**

Questions and Answers

Q1: Could you please let me know the budget for this project?

A1: The total amount awarded by the Florida Department of Environmental Protection is \$459,547.00 to include both construction and CEI Services.

Q2: Does the asphalt have to be placed in two one-inch lifts, or can it be placed in one two-inch lift?

A2: The asphalt must be placed in two 1” lifts.

Q3: Can hydro seeding be used in lieu of performance turf?

A3: Hydroseeding will be accepted in place of performance turf.