

ITB 2023-40 Medart Recreation Park Pond Construction
Addendum No. 1



**Addendum No. 1 ITB 2023-40
MEDART RECREATION PARK POND CONSTRUCTION**

Issued January 9, 2024

SECTION 1.0 SCHEDULE OF EVENTS

Failure to comply with this or any other paragraph of this ITB shall be sufficient reason for rejection of the Bid.

All times listed in the Schedule of Events are Eastern Standard Time (EST).

Event	Date/Time
Bid Advertisement Date	December 21, 2023
Release of Invitation to Bid	December 21, 2023
Questions Due from Prospective Bidder	January 3, 2024 @ 5:00 P.M.
Responses to questions due	January 9, 2024
BIDS DUE TO BOCC	January 16, 2024 @ 3:00 P.M.
Posting of Intended Award	January 23, 2024
Board Consideration of Intended Award	February 5, 2024
Posting of Notice of Award	February 6, 2024

This addendum is being posted to provide responses to the questions that were received.

**ITB 2023-40 Medart Recreation Park Pond Construction
Addendum No. 1**

Questions due January 3rd and responses to proposal questions due on or before January 9th

Questions and Answers

Q1: Does the 6,750 cy of excavation indicated in the basis of bid include any swell factor and if so, how much?

A1: No. This quantity is based on the difference in the existing and proposed surfaces, as calculated by the computer model.

Q2: Is there a list of qualified pond liner installers available?

A2: The County does not have a list of liner installers.

Q3: Is there a geotechnical report available for this site?

A3: No geotechnical data was collected at this site.

Q4: Is the County responsible for furnishing & installing the fence?

A4: Yes. The County will install the fence.

Q5: What is the project budget?

A5: The estimated budget for this project is \$65,000.00.

Q6: Can you provide the geotechnical report?

A6: No geotechnical data was collected at this site.

Q7: There is not a pay item to remove the existing concrete pad and sidewalk indicated in Sheet C4.0. Will the price of this item be included in the mobilization item, or will a new item be added?

A7: No. The county will self-perform the demolition shown on sheet C4.0.

Q8: Is the concrete flume part of the scope of this bid, or will it be done by others?

A8: The County will construction this following the installation of the influent line.