



**Addendum No. 1 to RFQ 2022-32  
Professional Engineering Services Elevated Aluminum Platforms for  
Lift Stations 8, 9 and 34**

*Issued November 3, 2022*

**SECTION 1.0 SCHEDULE OF EVENTS**

Failure to comply with this or any other paragraph of this ITB shall be sufficient reason for rejection of the Bid.

***All times listed in the Schedule of Events are Eastern Standard Time (EST).***

<i>Event</i>	<i>Date/Time</i>
Proposal Advertisement Date	October 13, 2022
Release of Request for Proposals	October 13, 2022
<b>Mandatory Pre-Bid Meeting and Site Visits**</b>	<b>October 20, 2022 @ 10:00 a.m.</b>
Questions Due from Prospective Respondent	October 27, 2022 by 5:00 p.m.
Responses to questions due	November 3, 2022
<b>PROPOSALS DUE TO BOCC</b>	<b>November 10, 2022 by 3:00 p.m.</b>
Oral Presentations (if needed)	November 17 – November 18, 2022
Posting of Selection Committee Rankings	November 18, 2022
Board Consideration of Selection Committee Rankings and Authorization to Enter Into Negotiations	December 12, 2022
Posting of Intended Award	December 13, 2022
Board Consideration of Intended Award	January 3, 2023
Posting of Notice of Award	January 4, 2023

**This addendum is being posted to provide responses to the questions that were received.**

## RFQ 2022-32 ADDENDUM NO.1

### Questions due October 27<sup>th</sup> and responses to proposal questions due on or before November 3<sup>rd</sup>

#### Questions and Answers

Q1: Would Wakulla be willing to open up their spec to allow a pump company outside of KSB bid on these jobs?

A1: No. Wakulla County standardizes its pumps and controls to streamline maintenance and reduce the amount and variability of repair parts to keep in stock. The County standard is a KSB submersible pump, stations 5HP or smaller in the Panacea Coastal area receive Shinmaywa pumps for Storm Mitigation purposes and insurance simplification.